

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0047:002 Page 1 of 1

CATEGORY: Door Closers/ HOLDERS

LISTEE: Rixson-Firemark, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101 Fax (704) 226-6198

DESIGN: Model F27 pocket door closer and Model FM51 floor type closer. Model F27 is factory adjusted and sealed unit that provides 12 lbs. pressure against opening measured at normal knob location on 3' x 7' door and 15-16 lbs. on a 4' x 7' door. Model FM51 is factory adjusted to provide a 10 lbs. closing force. It can be adjusted to provide hold-open force of 17-18 lbs. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a fire-rated door closer/holder. May be used without a latching device only on 1/3-hour fire-rated doors. Model FM51 must be used in conjunction with separately listed compatible releasing devices.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager